

ADDENDUM

Owner Contractor
Architect Field

Project Name: Field House – Press Box & Toilets
Canadian ISD
Canadian, TX

Addendum No.: **Three (3)**
Date: January 30, 2009
Project No.: 07008.9

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it has been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

General Items:

Item No. One: In the Specifications, Section 00030 – Notice To Bidders, For clarification purposes change the bid date from February 3 to February 10. Bid must be received at the time and location previously posted.

Item No. Two: In the Specifications, Section 15841 – Low Pressure Ductwork, For clarification purposes add the following item;

9.3.5 "BC" (Adjustable Blade, Ceiling) Grilles: Provide square housing, core of concentric adjustable blades and opposed blade damper.

Manufacturer: Metalaire LTC Series

Surface-mount.

Color: Satin aluminum.

Material: Aluminum only (steel not acceptable)

Pattern: 3-way