

# ADDENDUM

Owner  Contractor   
Architect  Field

Project Name: Field House – Press Box & Toilets  
Canadian ISD  
Canadian, TX

Addendum No.: **Four (4)**  
Date: January 30, 2009  
Project No.: 07008.9

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it has been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

## General Items:

**Item No. One:** In the drawings, Sheet E4 – Panel Schedules, Provide a 1000A main breaker in panel 09MDP instead of the MLO called for on the drawings.