

# ADDENDUM

Owner  Contractor   
 Architect  Field

Project Name:	Project Name: Enclosed Commons	Addendum No.:	<b>Three (3)</b>
	Owner's Name: Grady ISD	Date:	3/19/10
	Street Address: 3500 FM 829.	Project No.:	07031.7
	City, State Zip: Lenorah, Texas 79749		

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it has been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

## General Items:

- Item No. One:** Replace Addenda Two (2)- Item 1 with the following:  
 In the Specifications; Section 05300 – Metal Roof Decking, for clarification purposes omit references to galvanized decking and provide factory primed decking at the exposed area of Commons A104.
- Item No. Two:** In the Drawings, Sheet S3- Existing Roof Framing Detail; for clarification purposes length of new roof joist to be located at existing RTU's are as follows:
- A. North Wing (Classrooms A111, A114, A116, A119) - 26'-0"
  - B. South Wing (Classrooms A133, A138, A141, A147) - 24'-0"
  - C. East Wing (Classroom A102, Library A108) - 30'-0"
  - D. West Wing (Office A122, Classroom A132) - 26'-0"
- (Ref. Sheet A3- Floor Plan, Sheet A9-Roof Plan)

END OF ADDENDUM