



# PRESERVATION ASSOCIATES

21103 FM 179

Wolfforth, Texas 79382

Telephone: (806) 863-2462

Fax: 863-2479

---

## ADDENDUM

Owner  Contractor   
Architect  Field

---

Project Name: Roberts County Courthouse  
Historic Restoration  
Miami, Texas

Addendum No.: **Three (3)**

Date: Nov 26, 2008

Project No.: 03133

---

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it has been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

---

- Item No. One:** Section 16510, Light fixture "FO": On page 16510-1, para 5.2, change the catalogue number to indicate 2-32W TRT lamps.
- Item No. Two:** Section 16510, Delete light fixture "FT": On page 16510-2, delete para 5.4 (there are no "FT" fixtures on the job).
- Item No. Three:** Section 16510, Light fixture "FX": On page 16510-2, para 5.7 indicate the fixture wattage will be 130w.
- Item No. Four:** Section 16510, Light fixture "FY": On page 16510-2, para 5.8, replace the original light fixture information with the following:  
5.12 "FY"..  
Manufacturer: Teddico  
Catalog Number: VXWG-22-G  
Watts: 200W  
Lamps: Incandescent/screw-in fluorescent  
Mounting: Wall
- Item No. Five:** Section 16510, Update fixture information for "H": On page 16510-3 change the catalogue number and lamp information as follows:  
5.10 "H"..  
Catalog Number: SC1-C1NA-16-ABR-2TT32-120-EMI  
Lamps: 2-32W TT
- Item No. Six:** Section 16510, Update fixture information for "H3": On page 16510-3 change the catalogue number and lamp information as follows:  
5.11 "H3"..  
Catalog Number: SC1-P1AA-16-ABR-4QD26-120-EMI  
Lamps: 4-26W QD
-



# PRESERVATION ASSOCIATES

21103 FM 179

Wolfforth, Texas 79382

Telephone: (806) 863-2462

Fax: 863-2479

- 
- Item No. Seven:**     **Section 16510, Add light fixture “FP”:** On page 16510-3 add the following paragraph:  
*5.12 “FP” Spec grade recessed fluorescent quad-tube wet-location “can” light, consisting of thermally protected housing, die-cast aluminum mounting frame, factory-installed expandable bar hangers, high power factor ballasts, and flex conduit connection to socket housing. Trim assembly shall be recessed Fresnel glass lens.*  
Manufacturer: Lithonia  
Catalog Number: "LP6F-26-42TRT-MVlt-6L4  
Watts: 26-42W  
Lamps: 1-26-42W TRT  
Mounting: Plaster
- Item No. Eight:**     **Section 16510, Update fixture information for “H2”:** On page 16510-4 change the fixture information as follows:  
8.1 “H2”...  
Manufacturer: Rejuvenation  
Catalogue Number: Irvington C989-4
- Item No. Nine:**     **Section 16510, Status of fixture “H4”:** This fixture has not been selected yet. It will be a pendant-and/or cord-mounted incandescent fixture. Include in bid the cost for installation. Construction manager will provided the light fixtures.
- Item No. Ten:**     **Section 16510, Delete light fixture “IC”:** On page 16510-4, delete para 8.4 (there are no “IC” fixtures on the job).
- Item No. Eleven:**   **Drawing E2, Light fixtures for exterior, basement-level areaways:** Change the designation of the downlights serving the north and south basement-level areaways to “FP” (the designation had previously been “FO”).
- Item No. Twelve:**   **Drawing E2, Light fixtures above counters in toilets:** Change the designation of the downlights above the counters in the women’s toilet to “IS” (the designation had previously been “FS”).
- Item No. Thirteen:** **Drawings E2 and E3, Delete light fixtures in vaults:** Delete all type “IA” fixtures in vaults and the associated circuits and switches.

END OF ADDENDUM