

ADDENDUM

Owner Contractor
 Architect Field

Project Name:	2010 Improvements A New Food Bank & Youth Center Finish Out For Culberson County Van Horn, Texas	Addendum No.: Three (3) Date: Project No.:
---------------	---	---

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it has been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

- Item No. One:** Lighting: In the Specifications, Section 16510 – Building Lighting, add the following fixture.
 5.6 "FH": Spec grade surface-mounted steel-sided fluorescent light. Provide with steel-sides, opposing, rotary-action cam latches; door from hinged or latched from either side; frame corners screwed together; gasket between door and frame; hinged and latched wireway; pressure-lock lamp holders; regressed aluminum frame.
 Manufacturer: Lithonia
 Catalog Number: 2M-432-RW-A12.125-120-ES
 Watts: 150W
 Lamps: 4-F32RST8CW
 Mounting: Surface
- Item No. Two:** Food Bank Accessible parking: On Drawings SD1, show the two accessible parking spaces as being 11'0" wide x 20'0" long. Provide aluminum signs on galvanized steel posts centered on each parking aisle. Provide 12" diameter x 24" deep concrete foundations for the posts. Ensure the signs and the installation comply with Texas Accessibility Standards (TAS). Provide 5'0" wide x 20'0" long concrete unloading aisle.
- Item No. Three:** Food Bank Toilet: Increase the size of the toilet room to 6'0" x 6'0". Set the north/south dimension on the office at 7'-0". Provide plastic signage at the toilet room door that complies (size, pictology and location) with TAS.
- Item No. Four:** Food Bank Lighting: In the Drawings, Sheet ME1, Food Bank – Lighting Plan, change light fixture "FN" in Bathroom to a wall mounted "FE" fixture.
- Item No. Five:** Youth Center Parking Lot: On Drawing C1, delete any reference to the asphalt or the site concrete being provided by the Owner. Include these components in the bid.
- Item No. Six:** Youth Center Millwork: Provide millwork tops that are 34" from front-to-rear or as otherwise required to give the knee clearance as required by the TAS.

END OF ADDENDUM