

---

# ADDENDUM

Owner  Contractor   
Architect  Field

---

Project Name: 2010 Improvements  
Event Center and Rodeo Arena  
For Borden County  
Gail, Texas

Addendum No.: **Three (3)**  
Date: April 13, 2010  
Project No.: 09115

---

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it has been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

---

- Item No. One:** In addenda 01, Item 2, for clarification purposes modify fixture "MS" as follows;
- A. Quantity of fixture per Pole: 3 fixtures per pole, as required to ensure an average 15 fc lighting level.
  - B. Pole: Valmont or approved equal, the pole shall be a 60'-tall, round, tapered, metal, raceway-type lighting poles and standards comprised of shaft and mounting cage; equip with grounding connection readily accessible from handhole and construct of galvanized steel with galvanized finish. Design pole to withstand 100 MPH winds (plus 1.3 gust factor) as adjusted for height above ground level.

END OF ADDENDUM