

ADDENDUM

Owner Contractor
Architect Field

Project Name: Courthouse Renovations
Hansford County
16 Northwest Court Street
Spearman, Texas 79081

Addendum No.: Four (4)
Date: June 21, 2010
Project No.: 09148

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it has been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

General Items:

- Item No. One:** In the Specifications, Section 15770 – Split Systems; for clarification purposes provide the following;
- A. Furnace:** Provide condensing gas furnace with minimum heating efficiency of 92% AFUE.
 - B. Coil:** Change the part number on the schedules located on sheet M3 to CAP designated for R-410A refrigerant.
 - C. Air Cooled Condensing Unit:** Provide condensing unit with minimum seer-rating of 13.

END OF ADDENDUM