

# ADDENDUM

Owner  Contractor   
Architect  Field

---

Project Name: New Parking Lot & Playground Addendum No.: **One (1)**  
Amarillo Independent School District Date: May 27, 2010  
905 East Street Project No.: 10004  
Amarillo, Texas 79107

---

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it has been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

---

## General Items:

**Item No. One:** In the Specifications, Section 02920 – Lawns and Grasses, Paragraph 12.2.3, for clarification purposes the specifications state that the existing soil is to be loosened (scarify) to a depth of 6 inches deep. At this point 3 inches of washed and graded sand is to be placed over the entire playground area. The sand and existing soil are to be thoroughly mixed to a depth of 8 inches.

**Item No. Two:** In the Drawings, Sheet C1 – Site Plan, for clarification purposes the plans indicate a new 6 foot chain link fence to be installed completely around the playground area. On the north side of the playground area is a private residence. The existing fence adjacent to the school property at the private residence is to be removed by the contractor and the new 6 foot chain link fence is to be installed along the entire length of this property line. Coordination with the private residence is to be made through the school district's contact person prior to any demolition beginning. Installation of the new fence shall be connected back to the existing property fence as required to provide an enclosed yard area at the private residence.

END OF ADDENDUM